



National Transmission Corporation

17 May 2022

SUPPLEMENTAL BID BULLETIN ADDENDUM NO. 1

**SUBJECT : SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF
STATION BATTERIES**

Reference No. PB220413-EA30 / PR No. UMD-22-97600

TO ALL CONCERNED:

Please be informed of the following amendments to the Bidding Documents, as a result of the agreements reached during the 17 May 2022 Pre-Bid Conference at the GSD Conference Room, Ground Floor, TransCo Main Building, Quezon Avenue corner BIR Road, Diliman, Quezon City, and via Microsoft Teams.

ISSUES	AGREEMENTS
<ul style="list-style-type: none">Submission of Eligibility Documents (Statement of Single Largest Completed Contract (SLCC) Similar to the Contract to be Bid)	<ul style="list-style-type: none">➤ Single Largest Completed Contract (SLCC) similar to the contract to be bid must be within the last Ten (10) Years.
<ul style="list-style-type: none">Definition of Similar Contract	<ul style="list-style-type: none">➤ Supply, Delivery, Installation, Testing and Commissioning of Station Batteries.
<ul style="list-style-type: none">Delivery Period	<ul style="list-style-type: none">➤ One Hundred Fifty (150) Calendar Days reckoned from the acknowledgement of the Notice to Proceed (NTP).
Technical Specifications <ul style="list-style-type: none">Industrial Batteries Nominal CapacityDimension per cell	<ul style="list-style-type: none">➤ Minimum requirement: 220AH @ 10hr-rate to 1.8vpc.➤ Dimension per cell must not exceed: L 103mm x W 206mm x H 407mm

Thanks. Please be guided accordingly.


ATTY. SOLEDAD T. DE LA VEGA-CABANGIS
Chairperson
Bids and Awards Committee