



November 28, 2018

SUPPLEMENTAL/BID BULLETIN

ADDENDUM NO. 1

SUBJECT : CONSTRUCTION OF TRANSCO MINDANAO SATELLITE OFFICE BUILDING EXTENSION.

Reference No. PB1810724-RM65/MINSAT-18-95618

TO ALL CONCERNED:

Please be informed of the following amendments on the bidding Documents as result of the Pre-bid Conference held on November 27, 2018 at the TransCo Satellite Office, NPC Compound, Kumintang Street, Mintal Davao City.

ISSUES	AGREEMENTS														
<p>1. Technical Documents Requirements. <i>(page 116 of the Bidding Documents)</i></p>	<p>Amendments to Technical Requirements are as follows:</p> <table border="1" data-bbox="662 943 1442 1348"> <thead> <tr> <th data-bbox="662 943 828 976">Item No.</th> <th data-bbox="828 943 1131 976">FROM</th> <th data-bbox="1131 943 1442 976">TO</th> </tr> </thead> <tbody> <tr> <td data-bbox="662 976 828 1077">2</td> <td data-bbox="828 976 1131 1077">a. Duly signed Section VI. Schedule of Requirements.</td> <td data-bbox="1131 976 1442 1077">Not Required.</td> </tr> <tr> <td data-bbox="662 1077 828 1216">5</td> <td data-bbox="828 1077 1131 1216">S-curve or PERT/CPM or other acceptable tools of project scheduling.</td> <td data-bbox="1131 1077 1442 1216">S-curve shall be required</td> </tr> <tr> <td data-bbox="662 1216 828 1348">12</td> <td data-bbox="828 1216 1131 1348">PERT/CPM or other acceptable tools of project scheduling</td> <td data-bbox="1131 1216 1442 1348">PERT/CPM shall be required</td> </tr> </tbody> </table>			Item No.	FROM	TO	2	a. Duly signed Section VI. Schedule of Requirements.	Not Required.	5	S-curve or PERT/CPM or other acceptable tools of project scheduling.	S-curve shall be required	12	PERT/CPM or other acceptable tools of project scheduling	PERT/CPM shall be required
Item No.	FROM	TO													
2	a. Duly signed Section VI. Schedule of Requirements.	Not Required.													
5	S-curve or PERT/CPM or other acceptable tools of project scheduling.	S-curve shall be required													
12	PERT/CPM or other acceptable tools of project scheduling	PERT/CPM shall be required													
<p>2. Bill of Quantities <i>(page 100 & 101) of the Bidding Documents)</i></p>	<p>Amendments as follows on works to be done:</p> <table border="1" data-bbox="662 1435 1442 1939"> <thead> <tr> <th data-bbox="662 1435 938 1469" rowspan="2">Item No.</th> <th colspan="2" data-bbox="938 1435 1442 1469">Work to be Done</th> </tr> <tr> <th data-bbox="938 1469 1145 1503">From</th> <th data-bbox="1145 1469 1442 1503">To</th> </tr> </thead> <tbody> <tr> <td data-bbox="662 1503 938 1738"> <p>B3. Structural Works B. Concrete (211 kg/cm²), including formworks, decking (3000 PSI concrete)</p> </td> <td data-bbox="938 1503 1145 1738">Furnish,</td> <td data-bbox="1145 1503 1442 1738">Furnish, Construct except Rebars.</td> </tr> <tr> <td data-bbox="662 1738 938 1939">C.5 Boxes, fittings and accessories for fixtures, outlets, switches, and conduits</td> <td colspan="2" data-bbox="938 1738 1442 1939">100Ampere circuit breaker needed in replacement of existing 70Amp circuit breaker at the existing Main Electrical Panel must be reflected/included in the Detailed Estimates.</td> </tr> </tbody> </table>			Item No.	Work to be Done		From	To	<p>B3. Structural Works B. Concrete (211 kg/cm²), including formworks, decking (3000 PSI concrete)</p>	Furnish,	Furnish, Construct except Rebars.	C.5 Boxes, fittings and accessories for fixtures, outlets, switches, and conduits	100Ampere circuit breaker needed in replacement of existing 70Amp circuit breaker at the existing Main Electrical Panel must be reflected/included in the Detailed Estimates.		
Item No.	Work to be Done														
	From	To													
<p>B3. Structural Works B. Concrete (211 kg/cm²), including formworks, decking (3000 PSI concrete)</p>	Furnish,	Furnish, Construct except Rebars.													
C.5 Boxes, fittings and accessories for fixtures, outlets, switches, and conduits	100Ampere circuit breaker needed in replacement of existing 70Amp circuit breaker at the existing Main Electrical Panel must be reflected/included in the Detailed Estimates.														