

NATIONAL TRANSMISSION CORPORATION
RESOURCE MANAGEMENT SERVICES GROUP
TransCo Annex Bldg., Diliman, Quezon City
Tel. No. 902-1521/Fax No. 914-6209

SUPPLIER'S TECHNICAL/PRICE QUOTATION FORM
(NEGOTIATED PROCUREMENT: SMALL VALUE PROCUREMENT)

REFERENCE NO.: NP210623-PP043

FOR INQUIRIES, CONTACT PURCHASING OFFICER: **PINEDA, MA. PILAR L.**

Sir/Madam:

Please provide us with your best quotation and submit the same to the above assigned purchasing officer on or before 3:00 PM on quote closing date at PROCUREMENT MANAGEMENT DIVISION, Ground Floor, TRANSCO Main Building, Power Center, Quezon Avenue corner BIR Road, Diliman, Quezon City.

QUOTE CLOSING DATE/TIME: 06 OCTOBER 2021/3:00 P.M.

Deadline for submission may be extended if there are insufficient offers received. In case of a failed canvass, a re-canvass may be conducted without prior notice to any previous offeror (s).

Offers may be submitted in a sealed envelope, through fax or **through e-mail (mlpineda@transco.ph)** at the option of the offeror, properly marked with the reference number. This bid document comprises FIVE (5) pages including this sheet.

Please signify your acceptance of the TERMS AND CONDITION as stated herein, by signing on the space provided below and submit the signed copy together with your separate letter of quotation (as applicable).

Very truly yours,

ROGELIO M. MABULAY, JR.

Manager, Procurement Management Division

NOTE: THIS FORM IS COMPUTER GENERATED. SIGNATURE IS NOT REQUIRED.

NO.	DESCRIPTION	QUANTITY	ABC (VAT INC)	UNIT PRICE	TOTAL PRICE
				(VAT EXCLUSIVE, INDICATE APPLICABLE 12% VAT)	
1.	ROWAD-21-97152 / 1 POWER SUPPLY, UNINTERRUPTIBLE BASED ON TRANSCO CIRCULAR NO. 2020-005: POLICIES & GUIDELINES ON THE PROCUREMENT OF TRANSCO'S INFORMATION AND COMMUNICATIONS TECHNOLOGY (ICT) EQUIPMENT, RESOURCES, AND SERVICES (PLEASE SEE ATTACHED ATTACHMENT 11) BRAND/MODEL: _____	4 UNITS	₱ 20,000.00		
2.	OVP-TM-21-97331 / 1 POWER SUPPLY, UNINTERRUPTIBLE BASED ON TRANSCO CIRCULAR NO. 2020-005: POLICIES & GUIDELINES ON THE PROCUREMENT OF TRANSCO'S INFORMATION AND COMMUNICATIONS TECHNOLOGY (ICT) EQUIPMENT, RESOURCES, AND SERVICES (PLEASE SEE ATTACHED ATTACHMENT 11) BRAND/MODEL: _____	1 UNIT	₱ 5,000.00		

REFERENCE NO.: NP210623-PP043

NO.	DESCRIPTION	QUANTITY	ABC (VAT INC)	UNIT PRICE	TOTAL PRICE
				(VAT EXCLUSIVE, INDICATE APPLICABLE 12% VAT)	
3.	<p>CISIT-21-97434 / 1</p> <p>SUPPLY, DELIVERY, INSTALLATION, POWER UP AND TESTING OF 10KVA/10KW 230V UNINTERRUPTIBLE POWER SUPPLY (UPS) FOR DATACENTER</p> <p>OUTPUT: CAPACITY: 10KVA/10KW OUTPUT VOLTAGE: 220V/240V OUTPUT CONNECTIONS: (6) IEC 320 C13, (4) IEC 320 C19, (3) IEC JUMPERS LOAD CREST FACTOR: 3:1 TECHNOLOGY / TOPOLOGY: DOUBLE CONVERSION ONLINE EFFICIENCY AT FULL LOAD: 94% OUTPUT FREQUENCY (SYNC'D TO MAINS): 50 / 60 HZ, +/- 3HZ WAVEFORM TYPE: SINE WAVE BYPASS: AUTOMATIC / MANUAL OUTPUT VOLTAGE DISTORTION: LESS THAN 2%</p> <p>INPUT: NOMINAL INPUT VOLTAGE: 220V, 240V, 380V, 415V OTHER INPUT VOLTAGES INPUT FREQUENCY: 40-70 HZ AUTO-SELECTING INPUT VOLTAGE RANGE: 100-275 ADJUSTABLE VOLTAGE RANGE FOR MAIN OPERATION</p> <p>BATTERIES: BATTERY TYPE: MAINTENANCE-FREE SEALED LEAD-ACID BATTERY WITH SUSPENDED ELECTROLYTE, LEAKPROOF EXPECTED BATTERY LIFE: 3-5 YEARS RECHARGE TIME: 1.5 HOURS REPLACEMENT BATTERY: AVAILABLE BATTERY PACKS: 5 UNITS BATTERY PACK - STAND ALONE BATTERY STACK (TOWER TYPE)</p> <p>CONFORMANCE: - CE, CE MARK, EAC, EN/IEC 62040-1, EN/IEC 62040-2, IRAM, RCM, VDE - ROHS COMPLIANT</p> <p>COMMUNICATIONS AND MANAGEMENT: INTERFACE PORTS: RJ-45 10/100 BASE-T, RJ-45 SERIAL, USB CONTROL PANEL: MULTI-FUNCTION LCD STATUS AND CONTROL CONSOLE AUDIBLE ALARM: AUDIBLE AND VISIBLE ALARMS PRIORITIZED BY SEVERITY EMERGENCY POWER OFF: YES</p> <p>OTHER REQUIREMENTS: FORM FACTOR: EXTERNAL TOWER TYPE COLOR: BLACK - MUST PROVIDE BATTERY FAILURE NOTIFICATION AND PERIODIC BATTERY SELF-TEST - MUST BE MANAGEABLE VIA SERIAL PORT - MUST BE CAPABLE OF CENTRALIZED MANAGEMENT - MUST HAVE PREDICTIVE FAILURE NOTIFICATION</p>	1 LOT	₱ 900,000.00		

REFERENCE NO.: NP210623-PP043

NO.	DESCRIPTION	QUANTITY	ABC (VAT INC)	UNIT PRICE	TOTAL PRICE
				(VAT EXCLUSIVE, INDICATE APPLICABLE 12% VAT)	
3.	<p>Continuation</p> <ul style="list-style-type: none"> - MUST HAVE HO-SWAPPABLE BATTERIES - MUST BE COLD-START CAPABLE <p>CONTRACTOR REQUIREMENTS / SCOPE OF WORKS: WARRANTY: 3 YEARS WARRANTY FOR MAIN UPS AND INTERNAL BATTERY, 2 YEARS WARRANTY FOR EXTERNAL BATTERY WITH PHONE, E-MAIL AND ON-SITE SUPPORT - MUST INCLUDE AND PROVIDE ON-SITE SEMI-ANNUAL HEALTH CHECKS. - MUST PROVIDE KNOWLEDGE TRANSFER / TRAINING FOR ADMINISTRATORS / END-USER (INSTALLATION, CONFIGURATION, OPERATIONS AND BASIC TROUBLESHOOTING OF THE EQUIPMENT) TO NOT MORE THAN 5 PAX. MUST ALSO PROVIDE END-USER / ADMINISTRATOR MANUAL DOCUMENTATION AND CERTIFICATION. - UPS SYSTEM MUST WORK IN CONJUNCTION WITH EXISTING ELECTRICAL SYSTEM OF TRANSCO. - BIDDER MUST BE PARTNER PREMIER OF THE PRODUCT OFFERED TO ENSURE OF ITS TECHNICAL EXPERTISE ON THE OFFERED SOLUTION. COPY OF THE CERTIFICATE FROM THE MANUFACTURER MUST BE PROVIDED. - BIDDER SHOULD PROVIDE A CERTIFICATE THAT IT HAS 24/7 TECHNICAL SUPPORT CAPABILITIES. - BIDDER MUST HAVE AT LEAST ONE (1) EMPLOYED CERTIFIED DATA CENTER SPECIALIST (CDCS). CERTIFICATE OF EMPLOYMENT AND CDCS CERTIFICATE WITH LICENSE NUMBER AND EXPIRY DATE MUST BE SUBMITTED. - BRAND OFFERED MUST HAVE MANUFACTURING PLANT IN THE PHILIPPINES TO ENSURE PARTS AVAILABILITY IN CASE NEEDED. - BRAND OFFERED MUST HAVE LOCAL PRESENCE IN THE PHILIPPINES WITH TECHNICAL SERVICE SUPPORT SPEAKING THE LOCAL LANGUAGE. - THE BIDDER MUST HAVE AT LEAST ONE (1) EMPLOYED ELECTRICAL ENGINEER FULLY CERTIFIED BY THE VENDOR ON BRAND BEING OFFERED WITH A MINIMUM TWO (2) YAERS EXPERIENCE IN THE UPS-ELECTRICAL SYSTEM INSTALLATION, CONFIGURATION AND TROUBLESHOOTING. - BIDDER MUST HAVE AT LEASE ONE (1) EMPLOYED CERTIFIED UPS ENGINEER OF THE BRAND OFFERED.</p> <p>BRAND/MODEL: _____</p> <p>PLEASE REFER TO PAGE 4 FOR THE DOCUMENTS TO BE SUBMITTED TOGETHER WITH YOUR QUOTATION/PROPOSAL.</p>				

TOTAL AMOUNT (VAT EXCLUSIVE) _____

ADD: APPLICABLE VAT (___%) _____

TOTAL NET AMOUNT (VAT INCLUSIVE) _____

REFERENCE NO.: NP210623-PP043

NOTE : ALTERNATE OFFERS ARE NOT ALLOWED
Bids received in excess of the Approved Budget for the Contract (ABC) shall be automatically rejected.
SPECIAL INSTRUCTION: Interested suppliers must view/download the attached document in the Associated Component to be included in the Document Request List (DRL).

FIXED TERMS (PLEASE INCLUDE IN YOUR OFFER):

- **BID PRICE VALIDITY:** AT LEAST 60 DAYS FROM QUOTE CLOSING DATE
(VAT EXCLUSIVE, INDICATE APPLICABLE VAT)

- **DELIVERY PERIOD:** ITEM 1 & 2:
() SEVEN (7) CALENDAR DAYS FROM ACKNOWLEDGEMENT OF PO
() _____

ITEM 3:
() SIXTY (60) CALENDAR DAYS FROM ACKNOWLEDGEMENT OF PO
() _____

- **DELIVERY POINT:** TRANSCO-HEAD OFFICE, DILIMAN, Q.C. (C/O J.M. ILAGAN)

- **PAYMENT TERMS:** ITEM 1 & 2: WITHIN 30 CALENDAR DAYS UPON FULL DELIVERY AND ACCEPTANCE OF THE ITEM AND SUBMISSION OF COMPLETE REQUIRED DOCUMENTS.

ITEM 3: WITHIN 30 CALENDAR DAYS UPON FULL DELIVERY, COMPLETION AND ACCEPTANCE OF THE PROJECT AND SUBMISSION OF COMPLETE REQUIRED DOCUMENTS AND ISSUANCE OF CERTIFICATE OF ACCEPTANCE.

- **WARRANTY:** ITEM 1: _____
ITEM 2: _____
ITEM 3: _____

OTHER REQUIREMENTS/DOCUMENTS TO BE INCLUDED IN THE PROPOSAL:

- A. FOR ITEMS 1 & 2:**
 1. **Product brochures/catalog/technical reference.**
 2. Please indicate **BRAND/MODEL & WARRANTY** for each offer.

- B. FOR ITEM 3:**
 1. **Product brochures/catalog/technical reference.**
 2. Please indicate **BRAND/MODEL & WARRANTY** for each offer.
 3. **Certificate of Authorized Distributorship or Dealership in the Philippines issued by the Manufacturer, or in case of Reseller, Authorization to Bid issued by the Authorized Distributor/Dealer plus the Certificate of Distributorship or Dealership in the Philippines issued by the Manufacturer.**
 4. **Certificate that the Bidder shall provide a 24/7 Technical Support Capabilities.**
 5. **Certificate of Employment and CDS Certificate with license number and expiry date for the employed Certified Data Center Specialist (CDCS).**
 6. **Certification that the brand offered must have manufacturing plant in the Philippines to ensure parts availability.**
 7. **Certification that the brand offered must have local presence in the Philippines with technical service support speaking the local language.**
 8. **Certificate of Employment of Electrical Engineer for the brand being offered together with his/her Curriculum Vitae and copy of PRC license. The electrical engineer should have a minimum of two (2) year experience in the UPS-Electrical System Installation, Configuration and Troubleshooting.**
 9. **Certificate that the bidder has at least one (1) employed Certified UPS Engineer for the brand being offered.**

REFERENCE NO.: NP210623-PP043

ELIGIBILITY REQUIREMENTS/DOCUMENTS TO BE SUBMITTED BY THE AWARDEE PRIOR TO ISSUANCE OF NOTICE OF AWARD:

1. PhilGEPS Registration Number/Certificate of PhilGEPS Registration (for Platinum Membership)
2. DTI/SEC Registration Certificate
3. Mayor's Permit/Business Permit (2021)
4. BIR Certificate of Registration
5. Latest Income/Business Tax Return (2020)
6. Notarized Omnibus Sworn Statement (use applicable form)
7. Receipts must be BIR compliant (please see below).

Please issue an **Invoice/Receipt** to:

Name: National Transmission Corporation (TransCo)

Address: Power Center Agham Road Corner
Quezon Ave., Diliman Quezon City

TIN: 223-242-186-000

If transaction is subject to VAT, kindly show as separate item the VAT amount (12%) in the:

OFFICIAL RECEIPT - for sale of SERVICES
SALES INVOICE - for sale of GOODS or PROPERTIES

TRANSCO TERMS ACCEPTED: _____
(SIGNATURE AND DATE)

(NAME AND DESIGNATION)


(NAME OF COMPANY)

(MOBILE NO. & EMAIL ADD)

I. UNINTERRUPTIBLE POWER SUPPLY (POWER PROTECTION FOR DESKTOPS / WORKSTATIONS)


COMPONENT	TECHNICAL SPECIFICATION
POWER RATING (VA/W)	625 VA / 325 W
NOMINAL OUTPUT VOLTAGE (ON UTILITY)	230 V / 45-65 Hz
NOMINAL OUTPUT VOLTAGE (ON BATTERY)	220 V +/- 8%, 50 or 60 Hz +/- 1 Hz (AUTO-SENSING)
OUTPUT CONNECTIONS	3 "ASIA UNIVERSAL" OUTLETS (ALL WITH BATTERY BACKUP AND SURGE PROTECTION)
NOMINAL INPUT VOLTAGE	230 V / 45-65 Hz (AUTOMATIC VOLTAGE REGULATION)
INPUT CONNECTION	1 X 1.2 M POWER CABLE WITH NEMA 5-15P PLUG
AC POWER SURGE PROTECTION	ALL OUTLETS
BATTERY TYPE	MAINTENANCE-FREE, SEALED LEAD-ACID BATTERY, LEAK PROOF
BATTERY SIZE	12 VOLT, 7.0 Ah
CONTROL PANEL	LED STATUS DISPLAY WITH ON LINE, ON BATTERY, REPLACE BATTERY AND OVERLOAD INDICATED
AUDIBLE ALARM	ALARM WHEN ON BATTERY, DISTINCTIVE LOW BATTERY ALARM, OVERLOAD CONTINUOUS TONE ALARM
BIDDER/SUPPLIER REQUIREMENT	BIDDER/SUPPLIER SHOULD BE AN AUTHORIZED BUSINESS PARTNER AND AN AUTHORIZED SERVICE PROVIDER BRAND EQUIPMENT MUST HAVE SERVICE PRESENCE ON A NATIONWIDE BASIS
WARRANTY	TWO (2) YEARS WARRANTY (FREE PARTS, LABOR, AND IMMEDIATE REPLACEMENT UNIT WITH THE SAME SPECIFICATION) WITH FREE ONSITE TECHNICAL SUPPORT
PRICE PER UNIT	P 5,000.00

ENDORSED BY:


JANIE E. SERONIO
Manager, Corporate IS/IT



RECOMMENDED BY:


ATTY. REDENTOR S. TUAZON
Chief-of-Staff, Office of the President and CEO

APPROVED BY:


ATTY. MELVIN A. MAYIBAG
President and CEO

